



## ***SuperVault MH***

**Industrial Metal Fabricators  
Columbus, GA**

**SwRI ID No. 96040-04-03**

**Multi-Hazard Rated Protected Secondary Containment  
Aboveground Tank for Flammable and Combustible Liquids**

### **LISTED BY:**

**Southwest Research Institute  
San Antonio, Texas**

**This product has been evaluated for re-use after exposure to a fire, puncture, or heavy-vehicle impact. Should any of these occur, contact the manufacturer.**

SwRI is recognized as a testing laboratory  
and quality assurance/ inspection agency  
by the National Evaluation Service, Inc.

**This product has been listed after passing a 4-hour Fire Exposure Test, a Hose Stream Resistance Test, a Projectile Penetration Test, a Heavy Vehicle Impact Test, an environmental exposure evaluation, and an additional 2-hour Fire Exposure Test using the same, fully-assembled test tank for all tests.**

**Serial No.**

**This tank complies with the requirements of SwRI Test Procedure 95-03, SwRI Test Procedure 93-01, UFC79-7, UL 2085, and Interstitial Communication Test, and is a recognized listed product by Southwest Research Institute, San Antonio, Texas.**

**Manufactured under one or more of the following patents:  
United States Patent Nos. 5,038,456; 5,082,138; 5,092,024; and  
5,103,996. Manufactured under license from ITEQ Storage  
Systems, Inc.**